

## BRE Global

### UK Approved Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F1334

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1349 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

### Smart Connect Multiloop 10 Port, 1-9 Loop Analogue Addressable Control and Indicating Equipment with Printer

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

**Zeta Alarms Limited**  
**Detection House**  
**72-78 Morfa Road**  
**Swansea**  
**SA1 2EN**  
**United Kingdom**

**Zeta Alarms Limited**  
**Detection House**  
**72-78 Morfa Road**  
**Swansea**  
**SA1 2EN**  
**United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

### EN 54-2:1997 + A1:2006 Control and Indicating Equipment EN 54-4:1997 + A1:2002 + A2:2006 Power Supply Equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 10 December 2021 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



E. Mattie-Suleiman, Certification Engineer

On behalf of BRE Global Limited

Date of First Issue: 10 December 2021

Issue Date: 10 December 2021

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

**BRE Global**

**UK Approved Body No. 0832**

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

**APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1334**

**Smart Connect Multiloop 10 Port, 1-9 Loop Analogue Addressable Control and Indicating Equipment with Printer**

Incorporating the following modules:

MMP-DISP	Display PCB
MMP-TERM	Termination PCB
PCB MMP-TERM/EXP	Term Expander - 4 port
PCB/MMP-ZLX64	Zone LED Expansion PCB
PCB/PSU-UL-15	Power Supply Controller
BLD-400-V030-NNU	uPowerTek Power Supply Unit
SCM-LCM	Loop Card Module
SCM-ACM	Alarm Circuit Module

Optional modules:

SCM-NM	Network Module
SCM-ZMM	Six Way Zone Monitor Module
SCM-MIM	Six Way Multi Input Module
SCM-RM	Three Way Relay Module
SCM-PM	Printer Module


Ancillaries:

SMART/REP Smart Connect Multiloop LCD repeater

Incorporating the following modules:

MMP-DISP	Display PCB
MMP-REP_COM	Repeater communication PCB

Certified with the following options with requirements from EN 54-2: 1997:

  
E. Mattie-Suleiman, Certification Engineer  
On behalf of BRE Global Limited

Date of First Issue: 10 December 2021  
Issue Date: 10 December 2021  
Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

**BRE Global****UK Approved Body No. 0832**

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

**APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1334****Smart Connect Multiloop 10 Port, 1-9 Loop Analogue Addressable Control and Indicating Equipment with Printer**

- 7.8 Output to fire alarm device(s)
- 7.11 Delays to outputs
- 7.12.2 Dependencies on more than one alarm signal -Type B
- 7.12.3 Dependencies on more than one alarm signal -Type C
- 8.3 Fault signals from points
- 9.5 Disablement of each address point
- 10 Test condition

## Notes:

1. Scope of approval does not include the operation of the network functionality.
2. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.



E. Mattie-Suleiman, Certification Engineer

On behalf of BRE Global Limited

Date of First Issue: 10 December 2021

Issue Date: 10 December 2021

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)