

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00139

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): **Range of Premier Quatro Control and Indicating Equipment**
(refer to attached appendix for details and conditions)

Placed on the market under the name or trade mark of: **Zeta Alarms Limited**
Detection House, 72-78 Morfa Road, Hafod Swansea SA1 2EN, United Kingdom

and produced in the manufacturing plant(s): **Zeta Alarms Limited (SG- 11880)**
Detection House, 72-78 Morfa Road, Hafod Swansea SA1 2EN, United Kingdom

Intended use: **Fire Safety**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-2:1997+A1:2006
EN 54-4:1997+A1:2002+A2:2006

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00139** on **2015-07-02** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body


0905

Certification Manager: Dipl.-Ing. Roland Heine

Date Issue: 2019-10-21

Issue: 1

Signature:


91994



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00139

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00139

The details and conditions of use for the Range of Premier Quatro Control and Indicating Equipment , placed on the market under the name or trade mark of:

Zeta Alarms Limited

Detection House, 72-78 Morfa Road, Hafod, Swansea SA1 2EN, United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN 54-2:1997+A1:2006 and EN 54-4:1997+A1:2002+A2:2006

Model	Manufacturing Location	Description
QT/1 (37-500)	SG- 11880	Premier Quatro, 1 Loop Analogue Addressable Fire Alarm Panel Comprising of: - 21-3000 Controller PCB 21-502 Termination PCB 21-501 Display PCB 21-503 1 x Loop PCB MEBB Medium Enclosure Back Box MED Medium Enclosure Door MEMP Medium Enclosure Mounting Plate EXBP Backplate BB17 Battery Bracket SPX-150-30 150W Single Output Power Supply Batteries 2 x Power-Sonic 12V SLA Batteries (17Ah)
QT/2 (37-501)	SG- 11880	Premier Quatro, 2 Loop Analogue Addressable Fire Alarm Panel Comprising of: - 21-3000 Controller PCB 21-502 Termination PCB 21-501 Display PCB 21-503 2 x Loop PCB MEBB Medium Enclosure Back Box MED Medium Enclosure Door MEMP Medium Enclosure Mounting Plate EXBP Backplate BB17 Battery Bracket SPX-150-30 150W Single Output Power Supply Batteries 2 x Power-Sonic 12V SLA Batteries (17Ah)

Model	Manufacturing	Description
-------	---------------	-------------

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00139

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00139

	Location	
QT/3 (37-502)	SG- 11880	Premier Quatro, 3 Loop Analogue Addressable Fire Alarm Panel Comprising of: - 21-3000 Controller PCB 21-502 Termination PCB 21-501 Display PCB 21-503 3 x Loop PCB MEBB Medium Enclosure Back Box MED Medium Enclosure Door MEMP Medium Enclosure Mounting Plate EXBP Backplate BB17 Battery Bracket SPX-150-30 150W Single Output Power Supply Batteries 2 x Power-Sonic 12V SLA Batteries (17Ah)
QT/4 (37-503)	SG- 11880	Premier Quatro, 4 Loop Analogue Addressable Fire Alarm Panel Comprising of: - 21-3000 Controller PCB 21-502 Termination PCB 21-501 Display PCB 21-503 4 x Loop PCB MEBB Medium Enclosure Back Box MED Medium Enclosure Door MEMP Medium Enclosure Mounting Plate EXBP Backplate BB17 Battery Bracket SPX-150-30 150W Single Output Power Supply Batteries 2 x Power-Sonic 12V SLA Batteries (17Ah)

Options with requirements evaluated as being compliant:

Clause 7.8	Output to fire alarm devices
Clause 7.11	Delays to outputs
Clause 8.3	Fault signals from points
Clause 9.5	Disablement of addressable points
Clause 10.0	Test condition

Conditions of use:

Suitable for indoor applications

General Notes:

1. Evaluated under Intertek project number 10045205, 102031405, 103064316.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.