



The mentioned product complies with the mentioned test requirement

Intertek LSS Scheme Tick Mark Certificate

Certificate No. 13LHK1347 - 01

In accordance with the Tick Mark Rules and Certification System 5, as defined in ISO / IEC Guide 67, we certify that the product

Zeta Alarm Systems range of Simplicity Control and Indicating Equipment is in conformity with the following standard(s)

EN54-2:1997 + AC:1999 + A1:2006, EN54-4:1997 + AC:1999 + A1:2002 + A2:2006

Report Number: LHD10045204

Zeta Alarm Systems by GLT Exports Limited

Detection House, 72-78 Morfa Road, Hafod, Swansea, SA1 2EN, UK

is authorised to use the Intertek Tick Mark for the LSS Scheme on the above mentioned product

This certificate is valid until:

04 December 2016

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

Limitations:	Certification body: ITCL
	LSS Ref: LSS 0044
	Issued Date: 16 July 2013

Signed on behalf of Intertek, located at Leatherhead, United Kingdom

16 July 2013



010

R. Sodha

Rajesh Sodha

Certification Officer





The mentioned product
complies with the mentioned
test requirement

Intertek LSS Scheme Tick Mark Certificate

Certificate No. 13LHK1347 - 01

The tested product fulfills the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No 1

Zeta Alarm Systems range of Simplicity Control and Indicating Equipment

The optional features of the specifications that are included in the product and test report:

- 7.8 Output to fire alarm devices
- 7.12 Dependencies on more than one alarm signal
- 8.3 Fault signals from points
- 9.5 Disablement of addressable points
- 10 Test Condition

Ancillary Functions:

- Serial repeater output (RS485)
- Serial Output Port (RS232)

Brand and Type/Model	Description	Factory Code
Simplicity Plus 37-177	1 loop, 252 device CIE	GLTEXPUK.01
Simplicity Plus 37-176	1 loop, 126 device AA CIE	GLTEXPUK.01
Simplicity Plus 37-175	1 loop, 64 device CIE	GLTEXPUK.01



The mentioned product
complies with the mentioned
test requirement

Intertek LSS Scheme Tick Mark Certificate

Certificate No. 13LHK1347 - 01

The tested product fulfills the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No 2

Model Variants:

Variant	Model description
37-175	Simplicity Plus 1 loop, 64 device
37-176	Simplicity Plus 1 loop, 126 device
37-177	Simplicity Plus 2 loop, 252 device

Comprising of:

Part No.	Description
21-2006	Simplicity 2 Loop Termination PCB
21-2005	Simplicity 2 Loop Display PCB
21-3000	Controller pcb for EN54-4 LCD psu
SEEB	Small Enclosure back box
SED	Small Enclosure door
SEMP	Small enclosure mounting plate
CB	Cage bracket (for PSU controller)
BB12	Battery bracket for 12Ah batteries
RS-75-30	Sunpower 75W single output psu RS (SPX)-75-30
PS-12120B	Power Sonic 12V, 12Ah Sealed Lead Acid batteries (2-off)

To be used in accordance with the supplier's installation instructions

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.