

DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011

DoP Ref: GLT- 106b-DoP-1

1. Unique Product identification code:

37-175, 37-176, 37-177

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

SP/M-64 Simplicity Plus 1 loop 64 device analogue addressable fire alarm control panel
SP/M-126 Simplicity Plus 1 loop 126 device analogue addressable fire alarm control panel
SP/M-252 Simplicity Plus 2 loop 252 device analogue addressable fire alarm control panel

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems installed in and around buildings. (Indoor use only)

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Zeta Alarms Limited 72-78 Morfa Road Swansea SA1 2EN UK

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by the harmonized standard:

Intertek Life Safety and Security (Identification N0 0359) performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:

0359-CPD-145

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable, see item 7

Date: 13/10/2017 Page | 1 Issue: 2



9. Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. have been determined as described in the hEN mentioned in the following table.

| Essential | Perfor | Harmonized Technical Specification | |
|--|-----------|--|---|
| characteristics | mance | EN 54-2: 1997 + A1: 2006 | EN 54-4: 1997 + A2: 2006 |
| Operational reliability | Pass | 4 - General requirements | 4 - General requirements |
| | | 5 - General requirements for | 5 – Functions |
| | | indications | |
| | | 6 - The quiescent condition | 6 - Materials, design and |
| | | | manufacture |
| | | 7 - The fire alarm condition | 7 - Documentation |
| | | 8 - Fault warning condition | |
| | | 9 - Disabled condition | |
| | | 10 - Test condition (option with | |
| | | requirements) | |
| | | 12 - Design requirements | |
| | | 13 - Additional design requirements for | |
| | | software controlled control and | |
| | | indicating equipments | |
| | | 14 - Marking | 8 - Marking |
| Durability of operational | Pass | 15.4 - Cold (operational) | 9.5 - Cold (operational) |
| reliability Temperature resistance | | | |
| Durability of operational reliability Vibration resistance | Pass | 15.6 - Impact (operational) | 9.7 - Impact (operational) |
| | | 15.7 - Vibration, sinusoidal | 9.8 - Vibration, sinusoidal |
| | | (operational) | (operational) |
| | | 15.15 - Vibration, sinusoidal | 9.15 - Vibration, sinusoidal |
| | | (endurance) | (operational) |
| Durability of operational reliability Electrical stability | Pass | 15.8 - Electromagnetic Compatibility | 9.9 - Electromagnetic |
| | | (EMC), Immunity tests (operational) | Compatibility (EMC), Immunity tests (operational) |
| | | 15.13 - Supply voltage variation (operational) | |
| Durability of operational reliability Humidity resistance | Pass | 15.5 - Damp heat, steady state | 9.6 - Damp heat, steady state |
| | | (operational) | (operational) |
| | | 15.14 - Damp heat, steady state | 9.14 - Damp heat, steady state |
| | | (endurance) | (endurance) |
| Performance under fire | Pass | 4 - General requirements | |
| conditions | | 5 - General requirements for | |
| | | indications | |
| | | 7 - The fire alarm condition | |
| Response delay (response time to fire) | Pass | 7.1 - Reception and processing of fire | |
| | | signals | |
| | | 7.7 - Output of the fire alarm condition | |
| | | 7.11 - Delays to outputs (option with | |
| Performance of power supply | Deser | requirements) | 4. Compand as a viscous auto |
| | Pass | | 4 - General requirements |
| | | | 5 – Functions |
| | | | 6 - Materials, design and manufacture |
| OPTIONAL FUNCTIONS (OPT | TIONS WIT | | |
| Output to fire alarm Devices | Pass | 7.8 - Output to fire alarm Devices | |
| Delays to Outputs | Pass | 7.11 - Delays to Outputs | |
| Fault Signals from Points | Pass | 8.3 - Fault Signals from Points | |
| Disablement of Addr.Points | Pass | 9.5 - Disablement of addressable points | |
| Test Condition | Pass | 10 - Test Condition | |



10. The performance of the product identified in 1. and 2. is in conformity with the declared performance in 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of Zeta Alarms Limited by:

Name: N.R. P. Jones

Signature:

Position: Technical Manager

Place of issue: Swansea

Date of issue: 13th October 2017

Date: 13/10/2017 P a g e | **3** Issue: 2