

www.redbooklive.com

CERT

## **Certificate of Product Approval**

Certificate Number: 330r

Issue: 02

## Zeta Alarm Systems by GLT Exports

72-78 Morfa Road Swansea SA1 2EN United Kingdom

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

**Audible Warning Devices** 

MKII-AXT/R MKII-SSB MKII-AXT/W (Refer to Appendix for details)

#### Standards

EN 54-3:2001 + A1:2002 + A2:2006

P R E

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB	Martin McCullagh Verifier	20 May 2015 Date of Issue	04 July 20 Date of First	
	This certificate and appendix remain issued subject to terms and conditio <u>www.redbooklive.com/terms)</u> .	the property of BRE Global Ltd and are ns (for details visit		
	To check the validity of this certificate and appendix please visit <u>www.redbooklive.com/check</u> , scan the QR tag or contact us.			
0007	LPCB is part of BRE Global Ltd, Watf T: +44 (0)333 321 8811 F: +44 (0)1	ord, WD25 9XX 923 664603  E: <u>enquiries@breglobal.com</u>		Dre



800.8

# **LPCB**<sup>®</sup>

## Appendix to Certificate No: 330r Zeta Alarm Systems by GLT Exports

### Issue: 02

Certified Product	Description	LPCB Ref.No.
MKII-AXT/R	<ul> <li>Xtratone Addressable Type A Indoor Sounder (Red)</li> <li>Note:</li> <li>1. Meets the requirements of EN54-3 for the following tones:</li> <li>1) Alternating 800Hz/970Hz, 1Hz (500ms-500ms)</li> </ul>	330r/01
	2) Slow whoop 500Hz - 1200Hz, 3.5s sweep 0.5s silence, then repeat	
MKII-SSB	Fyreye II Sandwich Type A Indoor Sounder Base (MKII-AOP, MKII-AHR, MKII-AHF & MKII-AOH detectors & MKII-CB base) Note: 1. Meets the requirements of EN54-3 for the following tones: 1) Alternating 800Hz/970Hz, 1Hz (500ms-500ms)	330r/02
	2) Slow whoop 500Hz - 1200Hz, 3.5s sweep 0.5s silence, then repeat	
MKII-AXT/W	<ul> <li>Xtratone Addressable Type A Indoor Sounder (White)</li> <li>Note:</li> <li>1. Meets the requirements of EN54-3 for the following tones: <ol> <li>Alternating 800Hz/970Hz, 1Hz (500ms-500ms)</li> <li>Slow whoop 500Hz - 1200Hz, 3.5s sweep 0.5s silence, then repeat</li> </ol> </li> </ul>	330r/03

#### **Products Extras**

#### Bases/Detectors

MKII-CB	Shallow base
MKII-AOP	Fyreye II Addressable optical smoke detector
MKII-AHR	Fyreye II Addressable A1R heat detector
MKII-AHF	Fyreye II Addressable A2S heat detector
MKII-AOH	Fyreye II Addressable optical and heat detector

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB	Martin McCullagh Verifier	20 May 2015 Date of Issue	04 July 2014 Date of First Issue	
	This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).			
	To check the validity of this certificate and appendix please visit <u>www.redbooklive.com/check</u> , scan the QR tag or contact us.			
	LPCB is part of BRE Global Ltd, Wa T: +44 (0)333 321 8811 F: +44 (0	tford, WD25 9XX )1923 664603 E: <u>enquiries@breglobal.cor</u>	Dre	

80008

# **LPCB**<sup>®</sup>

## Appendix to Certificate No: 330r Zeta Alarm Systems by GLT Exports

### Issue: 02

#### Alternative Model No./Label

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
330r/01	MKII-AXT/R	16-140	Eurofyre Limited	330r-(cl-1)
330r/02	MKII-SSB	16-010	Eurofyre Limited	330r-(cl-1)
330r/03	MKII-AXT/W	16-141	Eurofyre Limited	330r-(cl-1)

#### Bases

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
330	MKII-CB	12-030	Eurofyre Limited	330
330	MKII-AOP	16-050	Eurofyre Limited	330
330	MKII-AHR	16-051	Eurofyre Limited	330
330	MKII-AHF	16-052	Eurofyre Limited	330
330	MKII-AOH	16-053	Eurofyre Limited	330

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB	Martin McCullagh	20 May 2015	04 July 2014
	Verifier	Date of Issue	Date of First Issue
	This certificate and appendix remain th issued subject to terms and conditions <u>www.redbooklive.com/terms)</u> . To check the validity of this certificate a <u>www.redbooklive.com/check</u> , scan the LPCB is part of BRE Global Ltd, Watford T: +44 (0)333 321 8811 F: +44 (0)192	(for details visit and appendix please visit QR tag or contact us. d, WD25 9XX	bre

BF1278A Rev. 0.6

80008