

Certificate of constancy of performance

0832-CPR-F0110

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

MKII-SSB Fyreye II Sandwich Type A Indoor Sounder Base

(For full product details and conditions of use refer to appendix)

Produced by or for

Zeta Alarms by GLT Exports Ltd

**Detection House
72-78 Morfa Road
Swansea
SA1 2EN
United Kingdom**

and produced in the manufacturing plant(s)

Zeta Alarms by GLT Exports Ltd

**Detection House
72-78 Morfa Road
Swansea
SA1 2EN
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006 - Sounders

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 04 July 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



M McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 04 July 2014
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F0110

Sounder Tones:

- 1) Alternating 800Hz/970Hz, 1Hz (500ms-500ms)
- 2) Slow whoop 500Hz - 1200Hz, 3.5s sweep 0.5s silence, then repeat

Bases/Detectors

MKII-CB	Shallow base
MKII-AOP	Fyreye II Addressable optical smoke detector
MKII-AHR	Fyreye II Addressable A1R heat detector
MKII-AHF	Fyreye II Addressable A2S heat detector
MKII-AOH	Fyreye II Addressable optical and heat detector



M McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 04 July 2014
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.