

Certificate of Product Approval

Certificate Number: 330q

Issue: 05

Zeta Alarms Limited

Detection House
72-78 Morfa Road
Swansea
SA1 2EN
United Kingdom



is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Heat Detectors

MKII-HF
MKII-HR
MKII-AHF
MKII-AHR
MKII-AHF/CS90
MKII-HF/CS90

(refer to Appendix for details)

Standards

EN 54-5:2000 + A1:2002

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

01 February 2018

Date of Issue

10 May 2013

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 330q

Issue: 05

Zeta Alarms Limited

Certified Product	Description	LPCB Ref.No.
MKII-HF	Fyreye II Conventional A2S Heat Detector (MKII-CB/D Base and MKII-CB Base) Note: 1. Meets the requirements of EN 54-5:2000 at Class A2S	330q/01
MKII-HR	Fyreye II Conventional A2R Heat Detector (MKII-CB/D Base and MKII-CB Base) Note: 1. Meets the requirements of EN 54-5:2000 at Class A2R	330q/02
MKII-AHF	Fyreye II Addressable A2S Heat Detector (MKII-CB/D Base and MKII-CB Base) Note: 1. Meets the requirements of EN 54-5:2000 at Class A2S	330q/03
MKII-AHR	Fyreye II Addressable A1R Heat Detector (MKII-CB/D Base and MKII-CB Base) Note: 1. Meets the requirements of EN 54-5:2000 at Class A1R	330q/04
MKII-AHF/CS90	Fyreye MKII Addressable Fixed Heat Detector 90 Degrees (MKII-CB/D Base and MKII-CB Base) Note: 1. Meets the requirements of EN 54-5:2000 at Class CS	330q/05
MKII-HF/CS90	Fyreye MKII Conventional Fixed Heat Detector 90 Degrees (MKII-CB/D Base and MKII-CB Base) Note: 1. Meets the requirements of EN 54-5:2000 at Class CS	330q/06

Bases

MKII-CB Shallow Base
MKII-CB/D Deep Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for BRE Global Ltd

P Halligan
Verifier

01 February 2018
Date of Issue

10 May 2013
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.

