



MANUFACTURERS OF FIRE ALARM EQUIPMENT

DECLARATION of CONFORMITY

The manufacturers (Zeta Alarms Ltd, 72-78 Morfa Road, Swansea, SA1 2EN) declares that

Conventional Manual Call Points

43-633	ZT-CP3/W	Zeta Conventional Surface Mount Call Point (White)
43-630	ZT-CP3/Y	Gas Extinguishing Call Point
43-631	ZT-CP3/B	Abort Call Point

Complies to the following standards:

Emission: EN61000-6-3 :2007

Immunity: EN50130-4 :2003

European Standard:

and thereby, complies with the ESSENTIAL REQUISITES of DIRECTIVE 2004/108/EC



A handwritten signature in blue ink, appearing to be "D. Zachariah", is written over the printed name.

For and on behalf of
Zeta Alarms Ltd
D. Zachariah
QUALITY ASSURANCE
MANAGER

Date: 11.09.2017